Energy performance certificate (EPC)

Electric Press 21 Henry Street Sheffield S3 7JT Energy rating

Valid until:	3 November 2032
Certificate number:	8589-1037-2203-9998- 5558


Property type	Residential spaces
Total floor area	3,103 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A+ to E.

Energy rating and score

This property's energy rating is B.



Properties get a rating from A+ (best) to G (worst) and a score.

The better the rating and score, the lower your property's carbon emissions are likely to be.

How this property compares to others

Properties similar to this one could have ratings:

If newly built	35 B
If typical of the existing stock	102 E

Breakdown of this property's energy performance

Main heating fuel	Natural Gas
Building environment	Heating and Natural Ventilation
Assessment level	4
Building emission rate (kgCO2/m2 per year)	38.19
Primary energy use (kWh/m2 per year)	223

Recommendation report

Guidance on improving the energy performance of this property can be found in the <u>recommendation</u> <u>report (/energy-certificate/7126-2053-8618-9485-5935)</u>.

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Bryan Wood
Telephone	01904 674890
Email	mail@thefesgroup.com

Contacting the accreditation scheme
If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd	
Assessor's ID	EES/013257	
Telephone	01455 883 250	
Email	enquiries@elmhurstenergy.co.uk	
About this assessment Employer	FES Construction Consultancy Group Ltd	
Employer address	Clifford Chambers, 4 Clifford Street, York, YO1 9RD	
Assessor's declaration	The assessor is not related to the owner of the property.	
Date of assessment	4 November 2022	
Date of certificate	4 November 2022	